



Columbia Area Office
1611 Chapin Road
Chapin, SC 29036
(803) 260-4532
(803) 422-7493

Charleston Area Office
226 N. Live Oak Drive
Moncks Corner, SC 29461
(843) 499-2756
(352) 397-8208

wmbeconsultants.com

Addendum No. 2

Date Issued: April 13, 2024
Project Name: SCC – P. Dan Hull Building Roof Replacement
Project Number: H59-6273 - PD
WMBE Project Number: 2023-47

This addendum modifies the Contract Documents as stated herein and shown on any accompanying drawings or attachments and is part of the Contract Documents.

Bidder shall acknowledge receipt of all addenda issued in the space provided on the Bid Form. Failure to acknowledge addenda may result in the bidders bid being rejected as non-responsive.

This addendum consists of 1 pages including attachments.

1. Changes to Bidding Requirements:

a. None.

2. Changes to Specifications: Section 075419 - Polyvinyl-Chloride (Pvc) Roofing

PART 1 – 1.11 WARRANTY

Special Warranty: Manufacturer agrees to repair or replace components of roofing system that fail in materials or workmanship within specified warranty period.

Warranty Period: 20 years Manufacturer’s Labor & Material No Dollar Limit Warranty dated the day of Substantial Completion or after.

A 90-mph wind speed rider shall be included.

3. Changes to Drawings:

a. None.