



## Addendum 1

SCC – Union Campus 105 Project

**Project Number:** SCC UCC 089

04/18/2024

- 1)** Question from Contractor: "I am working on the specs for the epoxy flooring for the above job. Do you have a thickness for the flooring epoxy? "

Answer: Follow manufacturers recommendations and apply a minimum of (2) coats to the floor. Allow each coat to dry for at least 12 hours but not more than 48 hours before applying an additional coat.

- 2)** Quote date is unchanged. Quotes are due on Tuesday, 04/30/2024 by 2:00 P.M.
- 3)** SE-331 must be used and emailed to [barberd@sccsc.edu](mailto:barberd@sccsc.edu).